

Builder Tip

VAPOUR BARRIERS FOR MEDIUM DENSITY (2LB CLOSED CELL) SPRAY-APPLIED POLYURETHANE FOAM INSULATION

Issue No: 34 Issued Nov. 2013 Revised May 2015 Updated to 2012 Building Code

ONTARIO BUILDING CODE

9.25.1.1. Scope and Application

(1) This section applies to heat, air and water vapour transfer and measures to control condensation.

9.25.4.2. Vapour Barrier Materials

- Vapour barriers shall have a permeance not greater than 60 ng/(Pa.s.m2), measured in accordance with ASTM E96/E96M, "Water Vapour Transmission of Materials", using the desiccant method (dry cup).
- (2) Where the intended use of the interior space will result in high moisture generation, the assembly shall be designed according to Part 5.
- (6) Where insulation functions as the vapour barrier, it shall be sufficiently thick so as to meet the requirement of sentence (1).

9.25.4.3. Installation of Vapour Barriers

- Products installed to function as the vapour barrier shall protect the warm side of wall, ceiling and floor assemblies.
- (2) Where different products are used for the vapour barrier and the insulation, the vapour barrier shall be installed sufficiently close to the warm side of the insulation to prevent condensation at design conditions.

(3) Where the same product is used for the vapour barrier and the insulation, the product shall be installed sufficiently close to the warm side of the assembly to prevent condensation at the design conditions.


OBJECTIVE

When using a medium density (2lb closed cell) Spray-Applied Polyurethane Foam Insulation (SPF) in a wall assembly with a minimum thickness of 50mm, the requirement for a vapour barrier could be eliminated where the thickness of 50mm of SPF provides the maximum permeance of 60 ng/(Pa.s.m2).

Caution: if the intent of the medium density spray foam is to be used as a vapour barrier and it is combined with batt-type insulation, then a vapour barrier would be required and sealed to prevent any vapour or moisture from condensing within the insulation and wall assembly.

In addition, where the SPF is used as the air barrier it must be continuous. To maintain a continuous air barrier, all wood to wood joints must be caulked with an acoustical sealant.

- Caulk between all studs and top/bottom plates.
- Seal all headers and top plates with acoustical sealant.
- Seal around door/window openings with polyurethane.
- Seal multiple plates with acoustical sealant or membrane.
- Seal multiple studs with sealant.



The Building Standards Department issues BUILDER TIPS as part of our customer service program. They are designed to provide an improved understanding of the Building Code and to reduce the costs associated with correcting infractions. Please contact your area building inspector for further information or call the Building Standards Department at (905) 475-4850